

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3210-1593:100

Page 1 of 1

CATEGORY: Fire Damper Operators

LISTEE: Belimo Aircontrols (USA), Inc., PO Box 2928 Danbury, CT 06813
Contact: Larry Felker (800) 987-9042 Fax (800) 987-8875

DESIGN: Models FSNF24 and FSNF120 followed by US or -S US electronic actuators. Units are motor- operated damper actuators with spring return mechanism for the operation of fire and combination fire and smoke dampers. Will meet requirements of UBC for 15 second opening and closing at 350 degree F. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as fire damper operators for use with fire and combination fire and smoke dampers. These devices are for on-off fail-safe control of damper in HVAC systems and similar applications. Authority having jurisdiction should be consulted prior to installation.

1-08-2003 IPI



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager